

# Circuit Breaker



## RCD OLL2 Circuit breaker

### **Technical Data:**

Standard: IEC1008,GB16916,BSEN61008

Rated Voltage( $U_n$ ): 2pole, 230VAC

4 pole: 400VAC

Rated Current( $I_n$ ): 25,40,63A

Rated residual operating current( $I_{\Delta n}$ ): 30,100,300,500mA

Rated residual non-operating current( $I_{\Delta n}$ ):  $0.5 I_{\Delta n}$

Residual current off-time: $\leq 0.1s$

Minimum value of rated making and breaking capacity( $I_m$ ): 1KA

Rated conditional short-circuit current( $I_{nc}$ ):  $I_n=25,40A I_{nc}=1500A$ ;  $I_n=63A$

$I_{nc}=3000A$

Installation: On symmetrical DIN rail